



PT Test Report



Site ID: 112914

Account No:

Customer:

Tech 1:

Test Date: Thursday, June 29, 2017 10:12:57 AM (UTC+06:00)

Tech 2:

Service: 3-Phase, 4-Wire, Wye (3V, 3C) TR

Sys ID: 7300-100155

Comments:

Transformer Information

Phase	Manufacturer	Catalog No	Serial No	NPR:1	Bur. Class	Acc. Class
A	ABB			175	75.0	0.3
B	ABB			175	75.0	0.3
C	ABB			175	75.0	0.3

Ratio at Zero Burden

	A	B	C
Measured	171.545	171.372	172.334
Error (%)	-1.974	-2.073	-1.524
Phase Error (Deg)	20.646	21.565	22.058
Phase Error (Min)	20° 38' 47"	21° 33' 55"	22° 3' 27"
Pri. Volts	19,290.039	19,314.240	19,220.551
Sec. Volts	112.449	112.703	111.531